

Entered 3/13/09

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

<b>NAME:</b> XTO ENERGY, INC
<b>ADDRESS:</b> 52260 WIK RD KENAI, AK 99611
<b>FACILITY:</b> EAST FORELANDS
<b>LOCATION:</b> 60° 31' 10" N; 151° 20' 31" W

(2-16)	(17-19)
AKG 31 5003	015
PERMIT NUMBER	DISCHARGE NUMBER

☐ CHECK HERE IF NO DISCHARGE

RECEIVED


MAR 13 2009

DEC

Division of Water Quality  
Wastewater Discharge Program

MONITORING PERIOD			
FROM	YEAR	MONTH	DAY
	2009	2	1
(20-21)	(22-23)	(24-25)	

TO	YEAR	MONTH	DAY
	2009	2	28
(26-27)	(28-29)	(30-31)	

(32-37) PARAMETER		QUANTITY OR LOADING (46-53)			QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO EX. (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		Average (54-61)	Maximum	Units	Minimum (38-45)	Average (46-53)	Maximum (54-61)	Units				
015 - Produced Water	FLOW	Sample Measurement	0.0972135	0.240702	MGD	***	***	***	***	0	Weekly	Estimate
		Permit Requirement	***	***		***	***	***		***	Weekly	Estimate
015 - Produced Water PRODUCED SAND		Sample Measurement	***	***	***	No discharge	No discharge	No discharge	***	0	***	***
		Permit Requirement	***	***		No discharge	No discharge	No discharge		***	***	***
015 - Produced Water OIL & GREASE		Sample Measurement	***	***	***	***	0	0	mg/l	0	Weekly	Grab
		Permit Requirement	***	***		***	29	42		***	Weekly	Grab
015 - Produced Water pH		Sample Measurement	***	***	***	7.5	***	7.6	SU	0	Weekly	Grab
		Permit Requirement	***	***		6	***	9		***	Weekly	Grab
015 - Produced Water TAH		Sample Measurement	***	***	***	***	16.898	16.898	mg/l	0	Monthly	Grab
		Permit Requirement	***	***		***	24	32		***	Monthly	Grab
015 - Produced Water TAqH		Sample Measurement	***	***	***	***	17.04	17.04	mg/l	0	Monthly	Grab
		Permit Requirement	***	***		***	Report	Report		***	Monthly	Grab
015 - Produced Water TOTAL AMMONIA		Sample Measurement	***	***	***	5.1	5.1	5.1	mg/l	0	Quarterly	Grab
		Permit Requirement	***	***		Report	***	Report		***	Quarterly	Grab
NAME TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.											
Ryan Tunseth HSE&T Coordinator												
Signature 											Telephone 907 776-2510	Date (YR/MO/DAY) 3/12/2009

**COMMENTS & EXPLANATION OF ANY VIOLATIONS:** WET Testing sampling frequency is reduced to once/6 months [Section II.G.6.a - Permit # AKG-31-5000] 1st Period 2009 WET tests were taken on 02/03/09 and are reported the Feb. 09 DMR. Additionally the sampling frequency for Copper, Manganese, Silver, Total Mercury, and Zinc is reduced from monthly to quarterly [Section II.G.6.a - Permit # AKG-31-5000] 1st Quarter 2009 sample results are shown.


**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

<b>NAME:</b> XTO ENERGY, INC
<b>ADDRESS:</b> 52260 WIK RD KENAI, AK 99611
<b>FACILITY:</b> EAST FORELANDS
<b>LOCATION:</b> 60° 31' 10" N; 151° 20' 31" W

(2-16) AKG 31 5003	(17-19) 015
PERMIT NUMBER	DISCHARGE NUMBER

<input type="checkbox"/>	CHECK HERE IF NO DISCHARGE
--------------------------	----------------------------

MONITORING PERIOD							
FROM	YEAR	MONTH	DAY	TO	YEAR	MONTH	DAY
	2009	2	1		2009	2	28
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)	

PARAMETER (32-37)		QUANTITY OR LOADING (46-53)			QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO EX. (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		Average (54-61)	Maximum	Units	Minimum	Average	Maximum	Units				
015 - Produced Water COPPER	Sample Measurement	***	***	***	***	4.11	4.11	ug/l	0	Quarterly	Grab	
	Permit Requirement	***	***		***	60	90		***	Quarterly	Grab	
	Sample Measurement	***	***		***	***	N/D		N/D	ug/l	0	Quarterly
015 - Produced Water MERCURY	Permit Requirement	***	***	***		0.5	0.8	***	Quarterly		Grab	
	Sample Measurement	***	***	***		***	1.65	1.65	mg/l		0	Quarterly
	015 - Produced Water MANGANESE	Permit Requirement	***		***	***	7.9	15.8		***	Quarterly	Grab
Sample Measurement		***	***		***	***	0.00	0		ug/l	0	Quarterly
015 - Produced Water SILVER		Permit Requirement	***	***		***	46	149	***		Quarterly	Grab
	Sample Measurement	***	***	***		***	0.0493	0.0493	mg/l		0	Quarterly
	015 - Produced Water ZINC	Permit Requirement	***		***	***	3.1	6.1		***	Quarterly	Grab
Sample Measurement		***	***		***	***	< 625	< 625		TUc	0	Semi Annual
015 - Produced Water WET - <i>Mytilus galloprovincialis</i> (invertebrate)		Permit Requirement	***	***		***	1209	2425	***		Semi Annual	Grab
	NAME TITLE PRINCIPAL EXECUTIVE OFFICER  Ryan Tunseth HSE&T Coordinator										Telephone  907 776-2510	
	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.									Signature 		
COMMENTS & EXPLANATION OF ANY VIOLATIONS: WET Testing sampling frequency is reduced to once/6 months [Section II.G.6.a - Permit # AKG-31-5000] 1st Period 2009 WET tests were taken on 02/03/09 and are reported the Feb. 09 DMR. Additionally the sampling frequency for Copper, Manganese, Silver, Total Mercury, and Zinc is reduced from monthly to quarterly [Section II.G.6.a - Permit # AKG-31-5000] 1st Quarter 2009 sample results are shown.												